

City of Waterbury bureau of water LCR 2022

Nr	ID	ADDRESS	DATE	PB(mg/L)	Cu(mg/L)
1	WBW027	118 ATWOOD AVENUE 06705	6/13/2022	0.001	0.05
2	WBW028	302 COURTLAND AVENUE 06705	6/22/2022	0.001	0.09
3	WBW029	586 HILL STREET 06704	7/5/2022	0.001	0.04
4	WBW030	140 JOSEPH STREET 06705	7/18/2022	0.001	0.09
5	WBW032	77 BUCKLAND DRIVE 06704	6/14/2022	0.001	0.03
6	WBW034	36 KENNETH CIRCLE 06710	6/23/2022	0.001	0.07
7	WBW036	40 ERMA DRIVE 06705	6/11/2022	0.001	0.16
8	WBW039	5 CRAIGIE AVENUE 06705	6/21/2022	0.001	0.10
9	WBW040	52 MACAULEY AVENUE 06705	6/22/2022	0.001	0.04
10	WBW041	38 STARLET LANE 06704	6/13/2022	0.001	0.03
11	WBW042	939 COOKE STREET 06704	8/23/2022	0.001	0.09
12	WBW043	194 DEVONWOOD AVENUE 06708	6/16/2022	0.001	0.05
13	WBW044	65 FOX RUN ROAD 06708	6/17/2022	0.001	0.06
14	WBW046	118 ALEXANDER AVENUE 06705	6/14/2022	0.0009	0.12
15	WBW050	12 BATESMOOR ROAD 06705	6/17/2022	0.001	0.08
16	WBW051	35 CESTARO STREET 06704	6/13/2022	0.001	0.15
17	WBW052	62 CHESTER AVENUE	6/13/2022	0.001	0.20
18	WBW053	50 FOX RUN ROAD 06708	7/8/2022	0.001	0.05
19	WBW054	253 GRASSY HILL ROAD 06704	6/13/2022	0.001	0.12
20	WBW055	953 BUNKER HILL AVENUE 06708	6/8/2022	0.001	0.07
21	WBW057	174 MANSFIELD AVENUE 06705	6/13/2022	0.001	0.07
22	WBW061	79 GRILLEYTOWN ROAD 06704	7/11/2022	0.001	0.15
23	WBW062	17 HEATON STREET 06705	6/13/2022	0.001	0.03
24	WBW064	106 OAK HOLLOW DRIVE 06708	8/18/2022	0.001	0.06
25	WBW065	136 LARCHMONT AVENUE 06708	6/10/2022	0.001	0.05
26	WBW067	417 PEARL LAKE ROAD 06706	6/13/2022	0.001	0.13
27	WBW069	359 MAYBROOK ROAD 06708	6/10/2022	0.0009	0.12
28	WBW070	101 RUMFORD STREET 06704	6/14/2022	0.001	0.11
29	WBW074	7 OLD COLONY DRIVE 06708	8/15/2022	0.003	0.10
30	WBW076	138 MONMOUTH AVENUE 06704	6/14/2022	0.002	0.13
31	WBW077	126 HORSESHOE DRIVE 06706	6/13/2022	0.001	0.07
32	WBW079	67 BUCKLAND DRIVE 06704	6/13/2022	0.001	0.08

PB	mg/L
Mean	0.001246154
Standard Error	0.000119497
Median	0.001
Mode	0.001
Standard Deviation	0.000861704
Sample Variance	7.42534E-07
Kurtosis	19.97178491
Skewness	4.278850517
Range	0.0051
Minimum	0.0009
Maximum	0.006
Sum	0.0648
Count	52
Lead 90th percentile Value 0.002 action level 0.015 mg/L	

Lead and Copper Survey 2020-2022

33	WBW081	119 ANNA AVENUE 06708	8/18/2022	0.001	0.12
34	WBW083	100 ATWOOD AVENUE 06705	6/14/2022	0.001	0.18
35	WBW084	149 PINERIDGE ROAD 06706	6/14/2022	0.001	0.04
36	WBW085	31 BRACKENRIDGE DRIVE 06706	6/20/2022	0.001	0.15
37	WBW086	57 STILLSON ROAD 06705	6/20/2022	0.001	0.10
38	WBW088	227 FOREST RIDGE ROAD 06708	8/22/2022	0.002	0.25
39	WBW089	1929 BALDWIN STREET 06706	6/15/2022	0.001	0.11
40	WBW090	76 HOUSTON STREET 06704	8/12/2022	0.001	0.02
41	WBW091	49 NATALIE TERRACE 06705	6/14/2022	0.001	0.06
42	WBW099	85 SOUTHRIDGE DRIVE 06708	6/16/2022	0.001	0.08
43	WBW100	333 BUNKER HILL AVENUE 06708	6/8/2022	0.001	0.07
44	WBW101	162 WESTRIDGE DRIVE 06708	6/9/2022	0.002	0.41
45	WBW103	21 JODIE CIRCLE 06706	7/7/2022	0.001	0.11
46	WBW104	177 ATWOOD AVENUE 06705	6/14/2022	0.001	0.05
47	WBW105	865 WOODTICK ROAD 06705	6/9/2022	0.001	0.11
48	WBW106	62 HORSESHOE DRIVE 06706	6/14/2022	0.001	0.02
49	WBW107	100 EASTRIDGE DRIVE 06708	6/10/2022	0.004	0.10
50	WBW109	20 FIRST AVENUE 06710	6/16/2022	0.001	0.10
51	WBW110	515 WILLOW STREET 06710	6/14/2022	0.001	0.23
52	WBW111	114 BIRCHFIELD DRIVE 06705	6/11/2022	0.006	0.33

<i>Cu</i>	<i>mg/L</i>
Mean	0.104423077
Standard Error	0.010280432
Median	0.09
Mode	0.05
Standard Deviation	0.074133252
Sample Variance	0.005495739
Kurtosis	5.910857143
Skewness	2.118181377
Range	0.39
Minimum	0.02
Maximum	0.41
Sum	5.43
Count	52
COPPER 90th percentile Value 0.18 action level 1.3 mg/L	